

Health Department, Haryana (Faridabad)

O/o Civil Surgeon, Faridabad

Hygiene Certificate

No. HHC/Far/2026/59.....

Date ...13.8.2026.....

Certified that the inspection of the .SHIRDI. SAI. BABA. SCHOOL.....


..SAI. DHAM. SECTOR. 06.1. FARIDABAD.....

.....School has been carried out on Date..13.8.2026.....The

Hygienic condition was found

satisfactory/Unsatisfactory

The above Certificate is valid till .31.03.2027... Date



Signature with Seal:
Dy. Civil Surgeon (School Health)
Faridabad

Memo No:- 1649

Date:- 14/11/2025

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	FBD/03466/11/2025	Sample Details	Date & Time
Sample Classification:	Private	Collected By	Sender Itself,9310801400
Sender:	Shirdi Sai Baba School	Collection Date	04/11/2025 at 16:00
Location :-	, Sai Dham, Sai Dham Marg, Sector 86	Received at lab	10/11/2025 at 11:13
Latitude :-	77.340271	Tested at Lab	14/11/2025
Longitude :-	28.409723		

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in FARIDABAD lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "**POTABLE**"



Vandana
VANDANA DESWAL,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY,FARIDABAD
email:-chemist.fbad@phedharyana.gov.in

-----End of Report-----.

Memo No:- 1647

Date:- 14/11/2025

Certificate
No: TC-9082

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : FBD/03465/11/2025 / Private	Sample Details	Date & Time
Sender : Shirdi Sai Baba School	Collected By	Sender Itself
Location : , Sai Dham, Sai Dham Marg, Sector 86	Collection Date	04/11/2025 at 16:03
Sample Description : Drinking Water	Received at lab	10/11/2025 at 11:13
Latitude / Longitude : 77.340273 / 28.409723	Analysis Start Date	12/11/2025
	Analysis End Date	13/11/2025
	Sample Quantity	1 Litre

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.21	1 NTU	5 NTU	APHA 24th edition ,2130 B:2023
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
4	Color	7	5 Hazen Units	15 Hazen Units	APHA 24 th EDITION- 2120 C:2023
5	Total Dissolved Solids @ 180°C ± 2°C	194	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCO ₃	110	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	24.04	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	12.15	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	80	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	110.72	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as SO ₄	23	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO ₄ -E
12	Fluoride as F	0.19	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition 4500 F-D:
13	Iron as Fe	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA 45(126:43459):2023, APHA 24th EDITION 3500-Fe-B
14	Nitrate as NO ₃	12.32	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
15	pH @ 25°C	7.10	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED FARIDABAD Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

VANDANA DESWAL, CHEMIST
DISTRICT WATER TESTING LABORATORY FARIDABAD
email:-chemist.fbad@phedharyana.gov.in